
8. Post-Reoccupation Surveillance

- Focused microbial sampling may be indicated to determine if:
 - The water in the facility's water distribution system meets the microbial standards of the Safe Drinking Water Act (see: <http://www.epa.gov/safewater/sdwa/index.html>);
 - Mold remediation efforts were effective in reducing microbial contamination in the affected areas of the hospital (see: http://www.epa.gov/mold/mold_remediation.html);
 - Residents who are receiving care in the reopened facility acquire infections that are potentially healthcare associated and that may be attributed to *Aspergillus* spp. or other fungi, non-tubercular mycobacteria, *Legionella*, or other waterborne microorganisms above expected levels